

[별표 3] (제5조제1항제1호 관련)

접합부 나사의 기준치수 및 공차

(단위 : mm)

호칭	구 분		암 나 사			A	N	P	di	DP	G
	나사 산수	소방용 수통과 지름	유효 지름	안지름 DB	콜지름 D						
25	8산/ 25.4mm	25.4	33.167 + 0.282 + 0	31.105 + 0.738 + 0	35.230 + 규정없음 + 규정없음	0	8.5	5	19.1	37	15
40	9산/ 25.4mm	38.1	48.971 + 0.392 + 0	47.752 + 0.924 + 0.010	50.8 + 규정없음 + 규정없음	1.5	8.5	5	38.1	52	15
65	7.5산/ 25.4mm	63.5	75.588 + 0.478 + 0	74.122 + 0.974 + 0.010	77.788 + 규정없음 + 규정없음	1.5	16	6.5	63.5	80	24
75	6산/ 25.4mm	76.2	89.677 + 0.457 + 0	86.925 + 1.068 + 0	92.428 + 규정없음 + 규정없음	2	18	7	76.6	96	27
90	6산/ 25.4mm	88.9	106.552 + 0.457 + 0	102.88 1 + 1.068 + 0	108.303 + 규정없음 + 규정없음	2	18	7	88.9	112	27
100	4산/ 25.4mm	101.6	123.787 + 0.635 + 0	119.66 2 + 1.552 + 0	127.912 + 규정없음 + 규정없음	2	18	7	103	131	27
115	4산/ 25.4mm	114.3	142.837 + 0.635 + 0	138.71 2 + 1.552 + 0	146.962 + 규정없음 + 규정없음	2	21	7	114. 4	150	30
125	4산/ 25.4mm	127	155.514 + 0.635 + 0	151.93 9 + 1.552 + 0	159.639 + 규정없음 + 규정없음	3	24	7	127	162	34
150	4산/ 25.4mm	152.1	174.945 + 0.635 + 0	170.82 0 + 1.512 + 0	179.070 + 규정없음 + 규정없음	3	24	7	152. 4	181	34

암 나 사

